



NOTES:

- 1) FOR APPROVED BEDDING AND BACKFILL MATERIAL AND COMPACTION REQUIREMENTS SEE NMWD SPECIFICATION C-2. UNLESS OTHERWISE APPROVED BY NMWD, BEDDING AND BACKFILL MATERIAL ARE THE SAME, COMMONLY KNOWN AS PEA AND SAND.
- 2) 1'-8" MIN. COVER DURING CONSTRUCTION.
- 3) PROVIDE A 3" THICK LIFT OF CLASS II AGGREGATE BASE WHERE THE TRENCH WILL BE OPEN FOR EXTENDED PERIODS OF TIME AND THE TRENCH BACKFILL MAY DETERIORATE DUE TO CONSTRUCTION TRAFFIC.
- 4) TRENCH RESTORATION AT EXISTING PAVEMENT TO BE IN ACCORDANCE WITH NMWD SPECIFICATION C-9, AND REQUIRED APPLICABLE CITY/COUNTY STANDARDS.
- 5) WHERE INDICATED ON THE PLAN, INSTALL 2" PVC SCH.40 CONDUIT FOR TELEMETERING CABLE.
- 6) # 10 AWG TW-SOLID LOCATING WIRE TAPED AT 10 FOOT INTERVALS ON NON METALLIC PIPE
- 7) 6-INCH WIDE BLUE WARNING/IDENTIFICATION TAPE.
- 8) AS REQUIRED BY NMWD. SEE CONSTRUCTION PLANS.

GENERAL NOTES:

- 9) NO PIPELINES, VALVES OR STRUCTURES SHALL BE BACKFILLED WITHOUT DISTRICT APPROVAL.
- 10) MAINTAIN MINIMUM POTABLE WATER, RECYCLED WATER AND SEWER LINE SEPARATION REQUIREMENTS PER CA. ADMIN. CODE 64630, TITLE 22. FOR ALL OTHER UTILITIES (E.G. STORM DRAIN, PRIVATE MAINS, GAS, ETC) MAINTAIN MINIMUM 5'-0" HORIZONTAL AND 1'-0" VERTICAL SEPARATION IN SEPARATE TRENCHES.

NORTH MARIN WATER DISTRICT NOVATO, CALIFORNIA			
TRENCH SECTION			
APPROVED 	DATE 05/16/07	REV. 3	STD. NO. 1

THIS STANDARD REPLACES NMWD STD-A-1