



ITEM:

PARTS LIST:

1	NIPPLE, FIELD FIT, MIN. 12" LONG (BRASS OR COPPER)
2	90° ELBOW (BRASS OR COPPER)
3	PIPE, FIELD FIT (BRASS OR COPPER), 10 ML TAPE AROUND PIPING IN CONTACT WITH CONCRETE SLAB
4	90° STREET ELBOW (BRASS OR COPPER)
5	DOUBLE CHECK (WILKINS 350XL OR APPROVED EQUAL) OR REDUCED PRESSURE PRINCIPLE (WILKINS 975XL2 OR APPROVED EQUAL) BACKFLOW PREVENTER. REFER TO APPROVED MATERIALS LIST.
6	6" NIPPLE (BRASS OR COPPER)
7	UNION FEMALE (BRASS)
8	NIPPLE, FIELD FIT (BRASS OR COPPER)
9	CONCRETE SLAB, 4" THICK BY 18" WIDE (MINIMUM)
10	ENCLOSURE CAGE OR INSULATION BLANKET

NOTES:

- REFER TO SECTION 15112 OF THE SPECIFICATIONS.
- NO OUTLET, TAP, TEE OR ANY OTHER TYPE OF CONNECTION WILL BE ALLOWED BETWEEN THE METER AND THE BACKFLOW ASSEMBLY. THE BACKFLOW DEVICE SHOULD BE INSTALLED AS CLOSE AS POSSIBLE TO THE METER. INSPECTION BY THE DISTRICT SHALL TAKE PLACE PRIOR TO BACKFILL (if possible).

NORTH MARIN WATER DISTRICT NOVATO, CALIFORNIA			
ABOVE GRADE BACKFLOW PREVENTER 3/4" THROUGH 2"			
APPROVED <i>[Signature]</i>	DATE 01/21/14	REV. 4	STD. NO. 19