



NOTES:

- 1) FOR WATER SERVICE INSTALLATION REFER TO NMWD STD. NO.15
- 2) REFER TO NMWD TECHNICAL SPECIFICATION P-7 FOR BACKFLOW DEVICE MATERIAL REQUIREMENTS.

PARTS LIST:

1	SHORT NIPPLE, 6" LONG (BRASS)
2	90° ELBOW (BRASS)
3	PIPE, FIELD FIT (BRASS)
4	UNION FEMALE (BRASS)
5	90° STREET ELBOW (BRASS)
6	DOUBLE CHECK BACKFLOW PREVENTER, (FEBCO MODEL 850 OR EQUAL), OR REDUCED PRESSURE BACKFLOW PREVENTER (WATTS MODEL 909 OR EQUAL)
7	CONCRETE SLAB, 4" THICK BY 18" WIDE (MINIMUM)

NORTH MARIN WATER DISTRICT
NOVATO, CALIFORNIA

**ABOVE GRADE BACKFLOW PREVENTER
3/4" THROUGH 2"**

APPROVED	DATE	REV.	STD. NO.
	05/03/02	1	19