



NOTES:

- 1) FOR VALVE RISER REFER TO NMWD STD.2, SIMILAR
- 2) ALONG STREETS WITH NO CURB OR SIDEWALK METER BOX SHALL BE INSTALLED AS FAR AS POSSIBLE AWAY FROM EDGE OF PAVEMENT AS DIRECTED BY THE DISTRICT.
- 3) FOR CONCRETE THRUST BLOCKING REFER TO NMWD STD.3
- 4) BEFORE BACKFILLING, PRIME AND COAL TAR WRAP FLANGES, BOLT RINGS AND EXPOSED STEEL PIPE.

PARTS LIST

1	6" GATE VALVE POxF OR 6" GATE VALVE FF (FOR STEEL MAIN)
2	6" 90° ELBOW FF
3	6" STEEL PIPE, CEMENT MORTAR LINED
4	6" SLIP-ON WELD FLANGE
5	6" BLIND FLANGE THREADED 4"
6	DUST CAP
7	4" BRASS NIPPLE WITH 4" FEMALE QUICK COUPLING
8	6" GASKET
9	3/4"x3-1/2" 316 S.S. BOLTS & NUTS
10	3" METER BOX WITH LID, CHRISTY B40 OR EQUAL

NORTH MARIN WATER DISTRICT
NOVATO, CALIFORNIA

6" BLOW-OFF ASSEMBLY
(FOR 12" MAINS AND LARGER)

THIS STANDARD REPLACES NMWD STD.-A-23
AND STD-A-24

APPROVED	DATE	REV.	STD. NO.
	7\19\02	1	7