



NOTES:

- 1) BEFORE BACKFILLING, PRIME AND COAL TAR WRAP EXPOSED STEEL PIPE AND TRANSITION COUPLING
- 2) FOR TRENCH SECTION REFER TO NMWD. STD. NO.1
- 3) USE ONLY WHERE:

MAIN	:	≤ 12" DIA.
PRESSURE	:	≤ 80 PSI
Δ	:	≤ 3'-0"

 LOCATION IS NOT NEAR A PUMP STATION
- 4) ALL STEEL PIPE AND ELBOWS TO BE CEMENT MORTAR OR EPOXY LINED.
- 5) PRESSURE TEST STEEL PIPE LOWERING PRIOR TO PLACING INTO SERVICE
- 6) STEEL LOWERING TO INCLUDE ANODE PER NMWD STD. NO.12
- 7) FOR CONCRETE ANCHOR BLOCKS FOR VERTICAL BENDS REFER TO NMWD STD. NO.4

NORTH MARIN WATER DISTRICT
NOVATO, CALIFORNIA

TYPICAL STEEL WATERMAIN LOWERING

APPROVED	DATE	REV.	STD. NO.
	5\16\02	1	10