



**NOTES:**

- 1) 1" WELDED OUTLET ORIENTED AS REQUIRED (HORIZONTAL OR @ 45°)  
ALL EXPOSED STEEL INCLUDING OUTLETS AND COUPLING TO BE PRIMED AND COAL TAR WRAPPED.
- 2) INSTALL INSULATOR COUPLING AT SERVICE LINE CONNECTIONS TO MANIFOLD.
- 3) FOR WATER SERVICE INSTALLATION REFER TO NMWD STD. NO.15
- 4) FOR 2" BLOW-OFF ASSEMBLY REFER TO NMWD STD. NO.6
- 5) INSTALL ANODE PER NMWD STD. NO. 12

NORTH MARIN WATER DISTRICT NOVATO, CALIFORNIA			
<b>4" STEEL MANIFOLD ASSEMBLY FOR MULTIPLE WATER SERVICE INSTALLATIONS</b>			
APPROVED	DATE	REV.	STD. NO.
	5\10\02	1	<b>14</b>

THIS STANDARD REPLACES NMWD STD-A-8