CONSTRUCTION REQUIREMENTS FOR WATER, RECYCLED WATER AND SEWER MAINS

CASE 1: NEW RECYCLED WATER OR SEWER MAINS ZONE

- A SPECIAL PERMISSION REQUIRED. DO NOT LOCATE ANY PARALLEL SEWER OR RECYCLED WATER MAINS IN THIS AREA WITHOUT DISTRICT AND STATE HEALTH DEPARTMENT APPROVAL
- B PVC SEWER PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR SEWER MAINS. C-900, DR14 OR C-905, DR18 PVC PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR RECYCLED WATER MAINS
- C A 20' CONTINUOUS SECTION OF PVC SEWER PIPE CENTERED AT THE MAIN BEING CROSSED OR SEWER PIPE INSTALLED IN A CASING (FOR SEWER MAINS)
 A 20' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- D A 8' CONTINUOUS SECTION OF PVC SEWER PIPE CENTERED AT THE MAIN BEING CROSSED, OR SEWER PIPE INSTALLED IN A CASING FOR (SEWER MAINS)

 A 8' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- P PROHIBITED ZONE; NO SEWER, WATER OR RECYCLED WATER MAINS; SECTION 64630 (E) (2) CALIFORNIA ADMINISTRATIVE CODE, TITLE 22

CONSTRUCTION REQUIREMENTS FOR WATER, RECYCLED WATER AND SEWER MAINS

CASE 2: NEW WATER OR RECYCLED WATER MAINS ZONE

- A SPECIAL PERMISSION REQUIRED. DO NOT LOCATE ANY PARALLEL WATER OR RECYCLED WATER MAINS IN THIS AREA WITHOUT DISTRICT AND STATE HEALTH DEPARTMENT APPROVAL
- B C-900 DR14 OR C-905, DR18 PVC PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR WATER MAINS
 C-900, DR14 OR C-905, DR18 PVC PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR RECYCLED WATER MAINS
- C A 20' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR WATER PIPE INSTALLED IN A CASING (FOR WATER MAINS) A 20' SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- D A 16' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR WATER PIPE INSTALLED IN A CASING (FOR WATER MAINS) A 16' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- P PROHIBITED ZONE; NO SEWER, WATER OR RECYCLED WATER MAINS; SECTION 64630 (E) (2) CALIFORNIA ADMINISTRATIVE CODE, TITLE 22

NORTH MARIN WATER DISTRICT NOVATO, CALIFORNIA			
WATER, RECYCLED WATER AND SEWER MAIN PARALLEL AND PERPENDICULAR SEPARATION NOTES			
APPROVED	DATE		STD. NO.
Z)m	12/28/10	0	NO. 31

DATE REVISED: 05/07